



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

DeRuyter Central Schools

Project Name: Drinking Water

Jody Van Dee
711 Railroad ST
DeRuyter, NY 13052

Project / PO Number: N/A
Received: 06/03/2025
Reported: 06/30/2025

Analytical Testing Parameters

Client Sample ID: Near Room 106 Across From Small Gym Bubbler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-01

Collected By: Jody Van Dee
Collection Date: 06/03/2025 4:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0050 AL	0.0010	mg/L	R3	06/25/25 1343	06/25/25 2020	DLO

Client Sample ID: Near Room 106 Across From Small Gym Bottle Filler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-02

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2025	DLO

Client Sample ID: Room 110 Bathroom Sink Student Medical
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-03

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.0050 AL	0.0015	mg/L		06/25/25 1343	06/27/25 1605	JDF

Client Sample ID: 112 Nurses Office
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-04

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2028	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID:	BTW Rooms 113 & 115 Bubblers	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:04
Lab Sample ID:	J5F0573-05		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2030	DLO

Client Sample ID:	BTW Room 113 & 115 Filler	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:05
Lab Sample ID:	J5F0573-06		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2031	DLO

Client Sample ID:	In Front of Room 123 Bubblers	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:08
Lab Sample ID:	J5F0573-07		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2036	DLO

Client Sample ID:	In Front of Room 123 Filler	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:08
Lab Sample ID:	J5F0573-08		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2037	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID: 123 Elem Room
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-09

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2040	DLO

Client Sample ID: Boys Bath 76 Wing Bubbler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-10

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2042	DLO

Client Sample ID: Boys Bathroom 76 Wing Filler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-11

Collected By: John Paley
Collection Date: 06/03/2025 5:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2044	DLO

Client Sample ID: Girls Bathroom 76 Wing Bubbler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-12

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2047	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID: Girls Bathroom 76 Wing Filler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-13

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2048	DLO

Client Sample ID: Water Fountain in Cafe Bubbler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-14

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2050	DLO

Client Sample ID: Water Fountain in Cafe Filler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-15

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2054	DLO

Client Sample ID: Drinking Fountain Inside Cafe
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-16

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2056	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID: Cafe Sink 2
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-17

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2058	DLO

Client Sample ID: Cafe Sink 3
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-18

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2059	DLO

Client Sample ID: Dishwasher Sink 4
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-19

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2101	DLO

Client Sample ID: Dishwasher Spray Hose
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-20

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0050 AL	0.0010	mg/L		06/25/25 1343	06/25/25 2039	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID:	Ice Machine	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:23
Lab Sample ID:	J5F0573-21		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2108	DLO

Client Sample ID:	Cafe Sink # 1	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:24
Lab Sample ID:	J5F0573-22		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2113	DLO

Client Sample ID:	Spray Hose Next to Sink # 1	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:25
Lab Sample ID:	J5F0573-23		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2114	DLO

Client Sample ID:	Warmer # 1	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:26
Lab Sample ID:	J5F0573-24		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0139	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2116	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID: Warner # 2

Sample Matrix: Drinking Water

Lab Sample ID: J5F0573-25

Collected By: Jody Van Dee

Collection Date: 06/03/2025 5:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2118	DLO

Client Sample ID: Fountain Near Boys Bathroom HS Gym Bubbler

Sample Matrix: Drinking Water

Lab Sample ID: J5F0573-26

Collected By: Jody Van Dee

Collection Date: 06/03/2025 5:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2119	DLO

Client Sample ID: Fountain Near Boys HS Gym Filler

Sample Matrix: Drinking Water

Lab Sample ID: J5F0573-27

Collected By: Jody Van Dee

Collection Date: 06/03/2025 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0128	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2124	DLO

Client Sample ID: Boys Bathroom Near Room 142 Bubbler

Sample Matrix: Drinking Water

Lab Sample ID: J5F0573-28

Collected By: Jody Van Dee

Collection Date: 06/03/2025 5:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0278	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2125	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID: Boys Bathroom Near Room 142 Filler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-29

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2127	DLO

Client Sample ID: Near Girls Locker Room Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-30

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2128	DLO

Client Sample ID: Fountain Near Boys Locker Room
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-31

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2130	DLO

Client Sample ID: Fountain Near Room 212 Bubbler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-32

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2133	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID:	Fountain Near Room 212 Filler	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:40
Lab Sample ID:	J5F0573-33		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2134	DLO

Client Sample ID:	Fountain Near Room 204 Bubbler	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:42
Lab Sample ID:	J5F0573-34		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2136	DLO

Client Sample ID:	Fountain Near Room 204 Filler	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:42
Lab Sample ID:	J5F0573-35		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2138	DLO

Client Sample ID:	Ag Room Bathroom	Collected By:	Jody Van Dee
Sample Matrix:	Drinking Water	Collection Date:	06/03/2025 5:50
Lab Sample ID:	J5F0573-36		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2142	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0573

Client Sample ID: Fountain Weight Room Bubbler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-37

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2144	DLO

Client Sample ID: Fountain Weight Room Filler
Sample Matrix: Drinking Water
Lab Sample ID: J5F0573-38

Collected By: Jody Van Dee
Collection Date: 06/03/2025 5:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/25/25 1354	06/25/25 2145	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level
mg/L: Milligrams per Liter
R3: Duplicate RPD is outside of acceptance criteria. The difference between the results is less than 2x Method Reporting Limit.
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Shannon Weeks

Shannon Weeks
Customer Relationship Coordinator
Reported: 06/30/2025 18:46

CHAIN OF CUSTODY RECORD

Number

Instructions on back

Lab Report Address

Client Name: DeRuyter Central School

Address: 711 Railroad St

City, State, Zip: DeRuyter NY 13052

Contact: Jocely Van Daele

Telephone No.: 315-852-3400 x 3701

Send Report via: ☒ Mail ☐ Fax ☐ e-mail (address)

Project:

Location: DeRuyter School

PO No.:

Sampled by (PRINT): Jocely Van Daele

Sampler Signature: *Jocely Van Daele*

Sampler Phone No.: 315-852-3400 x 7301

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **
1	Water room 106 ceiling	6/13/25	4:58 AM	X	Lead	Lead
2	Water room 106 ceiling	6/13/25	5:01 AM	X	Lead	Lead
3	Room 116 production tank	6/13/25	5:01 AM	X	Lead	Lead
4	Room 116 production tank	6/13/25	5:02 AM	X	Lead	Lead
5	Room 116 production tank	6/13/25	5:04 AM	X	Lead	Lead
6	Room 116 production tank	6/13/25	5:05 AM	X	Lead	Lead
7	Room 116 production tank	6/13/25	5:05 AM	X	Lead	Lead
8	Room 116 production tank	6/13/25	5:05 AM	X	Lead	Lead
9	Room 116 production tank	6/13/25	5:05 AM	X	Lead	Lead
10	Room 116 production tank	6/13/25	5:05 AM	X	Lead	Lead

Possible Hazard Identification

☒ Hazardous ☐ Non-Hazardous ☐ Radiactive

HNO3 ADDED TO SAMPLES - J502033 - RLF 06/06/25

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

Date/Time

Date/Time

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time

Turnaround Time

☒ Routine (5 to 7 business days)
☐ RUSH* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Compliance Monitoring? ☐ Yes ☐ No

Agency/Program

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 20.3°

Therm ID IR-2


Holding Time

Samples Received on Ice? ☐ Yes ☒ No ☐ N/A

Custody Seals Intact? ☐ Yes ☒ No ☐ N/A



DeRuyter Central Schools
 PM: Shannon Weeks



3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC
Temperature Upon Receipt (C)
Therm ID
Holding Time

RUF
06/03/25

Turnaround Time
☒ Routine (5 to 7 business days)
☐ RUSH* (notify lab)

Invoice Address

Client Name: De Ruyter Central School

Address: 711 Reuland St

City, State, Zip: De Ruyter NY 13528

Contact: Dedy Van Deen

Telephone No.: 315-852-3400 x 3701

Send Report via: ☒ Mail ☐ Fax ☐ e-mail (address)

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Compliance Monitoring? ☐ Yes ☐ No

Agency/Program

Sampler Phone No.: 315-852-3400 x 3701

Location: De Ruyter School

PO No:

Sampler Signature: [Signature]

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **
19	21 Dishwasher Sink	6/13/25	5:21am	x	Lead	Lead
20	22 Dishwasher Spray	6/13/25	5:21am	x	Lead	Lead
21	23 Ice Machine	6/13/25	5:23am	x	Lead	Lead
22	24 Canteen Sink	6/13/25	5:24am	x	Lead	Lead
23	25 Spray Mop	6/13/25	5:25am	x	Lead	Lead
24	26 Urn	6/13/25	5:26am	x	Lead	Lead
25	27 Urn	6/13/25	5:28am	x	Lead	Lead
26	28 Fountain near boys	6/13/25	5:30am	x	Lead	Lead
27	29 Fountain near boys	6/13/25	5:32am	x	Lead	Lead
28	30 Fountain near boys	6/13/25	5:33am	x	Lead	Lead
29	31 Fountain near boys	6/13/25	5:33am	x	Lead	Lead
30	32 Fountain near boys	6/13/25	5:33am	x	Lead	Lead

Possible Hazard Identification ☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time



DeRuyter Central Schools
PM: Shannon Weeks

RUF 06/03/25

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°F)

Therm ID

Holding Time

Samples Represerved on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Invoice via: ☐ Mail ☐ Fax ☐ e-mail (address)

Compliance Monitoring? ☐ Yes ☐ No

Agency/Program

Sampler Phone No.: 315-852-3400 x 3701

Sampler Signature: *Jody Van Dine*

Location: DeRuyter School

PO No:

Project:

Sampled by (PRINT): Jody Van Dine

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis



DeRuyter Central Schools
PM: Shannon Weeks

RUF 06/03/25

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time



Amanda Graham-Quirk <grahamquirk@deruytercentral.org>

Fwd: ENV Metals Report

1 message

Jody VanDee <vandee@deruytercentral.org>

Tue, Jul 22, 2025 at 9:49 AM

To: Amanda Graham-Quirk <grahamquirk@deruytercentral.org>

----- Forwarded message -----

From: **Cassandra Hinkle** <Cassandra.Hinkle@microbac.com>

Date: Tue, Jul 22, 2025 at 8:44 AM

Subject: ENV Metals Report

To: vandee@deruytercentral.org <vandee@deruytercentral.org>

Goodmorning Jody,

My name is Cassandra with Microbac in Cortland. We had just gotten off the phone, I have received the copy of your report. The Chain of Custody should also be at the end of this report as well. Please let me know if you have any questions or concerns.

Thank you and have a good day!

Cassandra Hinkle

Customer Relationship Associate

Microbac Cortland

CONFIDENTIALITY NOTICE: This e-mail message, and any documents, files or previous e-mail messages attached to it may contain confidential information. If you are not the intended recipient, please know that any disclosure, copying, distribution or use of any of the information contained in or attached to this transmission is STRICTLY PROHIBITED. If you have received this transmission by mistake, please immediately notify the sender. Please also destroy the original transmission and its attachments without reading or saving in any manner. We appreciate your cooperation. Thank you, Microbac Laboratories, Inc.

report_jody_vandee.pdf
3163K